

PERFORMANCE RESULTS

Tricel (Killarney)

Ballyspillane Industrial Estate, Killarney, Co. Kerry, Ireland

EN 12566-3: 2005+A1:2009

Results corresponding to the Irish National Annex for IS EN 12566-3

Puraflo small wastewater treatment system

Septic tank & Peat Bio-filter Modules, sewage treatment system

Nominal organic daily load*	0.33	kg/d		
Nominal hydraulic daily load	0.90	m ³ /d		
Material	Septic tank: glass reinforced plastic Peat filter: polyethylene (PE)			
Watertightness (water test)	pass			
Crushing resistance	Septic tank: calculation Peat filter: vertical load type A			
Durability	pass			
Treatment efficiency (nominal sequences)		Efficiency	Effluent	
	COD	95.4 %	31 mg/l	
	BOD ₅	98.2 %	6 mg/l	
	NH ₄ -N**	98.6 %	0.6 mg/l	
	SS	97.7 %	8 mg/l	
Electrical consumption	0.1	kWh/d		

* at a test influent of ≥ 300 mg/l BOD₅ (mean)
** determined for temperatures $\geq 12^{\circ}\text{C}$ in the bioreactor

Performance tested by:

PIA – Prüfinstitut für Abwassertechnik GmbH

(PIA GmbH)

Hergenrather Weg 30

D-52074 Aachen

This document replaces neither the declaration of conformity nor the CE marking



Notified Body
Nr.: 1739



Certified according to
ISO 9001:2000



Prüfinstitut für Abwassertechnik GmbH
Geprüft - tested - teste

Elmar Lancé

January 2016